

STATE OF VERMONT
PUBLIC SERVICE BOARD

Docket No. 7456

Petition of Vermont Gas Systems, Inc. for a certificate)
of public good, pursuant to 30 V.S.A. § 248(j),)
authorizing the rebuild and enclosure of an existing)
pressure-regulation station and the replacement of an)
existing communications building on Gorge Road in the)
City of Winooski, Vermont)

Entered: 9/3/2010

CERTIFICATE OF PUBLIC GOOD ISSUED
PURSUANT TO 30 V.S.A. SECTION 248

IT IS HEREBY CERTIFIED that the Public Service Board of the State of Vermont this day found and adjudged that the rebuilding by Vermont Gas Systems, Inc. ("VGS"), of the existing pressure-regulation station and the replacement of the existing communications building at its Winooski Gate Station in Winooski, Vermont, in accordance with the evidence and plans submitted in this proceeding, will promote the general good of the State, subject to the following conditions:

1. Construction, operation and maintenance of the project shall be in accordance with the plans and evidence submitted in this proceeding.
2. VGS shall comply with the construction requirements contained in the Vermont Department of Environmental Conservation's Low Risk Site Handbook for Erosion Prevention and Sediment Control.
3. VGS shall submit a demolition waste disposal plan as a compliance filing within 30 days of the issuance of the CPG for the Project.
4. If VGS's system-end-point pressures at either the Jericho Station or the Williston Station fall below 30 psig as a result of the construction of the Project, VGS shall evaluate the need to take corrective action, including initiating a system-reinforcement project, if warranted.
5. This Certificate of Public Good shall not be transferred without prior approval of the Board.

Dated at Montpelier, Vermont, this 3rd day of September, 2010.

s/ James Volz)
))
))
s/ David C. Coen)
))
))
s/ John D. Burke)

PUBLIC SERVICE

BOARD

OF VERMONT

OFFICE OF THE CLERK

FILED: September 3, 2010

ATTEST: s/ Susan M. Hudson
Clerk of the Board

NOTICE TO READERS: This decision is subject to revision of technical errors. Readers are requested to notify the Clerk of the Board (by e-mail, telephone, or in writing) of any apparent errors, in order that any necessary corrections may be made. (E-mail address: psb.clerk@psb.state.vt.us)